



**CITY OF CORONA
ADMINISTRATIVE SERVICES DEPARTMENT
PURCHASING DIVISION**

=====

June 20, 2017

SUBJECT: Notice Inviting Bids (NIB) No. 17-059CA

**ADDENDUM No. 2
CATIONIC/ANIONIC POLYMERS FOR WATER RECLAMATION**

This Addendum No. 2 to the subject Notice Inviting Bids provides responses to requests for information. The bid due date and time remains unchanged.

All provisions of and attachments to this Addendum No. 2 are hereby incorporated by reference into the subject NIB. Bidders shall account for all provisions pursuant to this Addendum No. 2 in submitting their bids. Each bidder shall acknowledge receipt of this Addendum in their bid in the spaces provided therein.

Responses to Questions:

2.22 Question: “If we need to submit the gal/hr of polymer, what are the flow rate for 3 applications: 1) Primary, 2) Thickener and 3) Belt Press?”

Answer: Primary: 3,850 gpm
 Thickener: 300 gpm
 Belt Press: 80 gpm

2.23 Question: “We have contacted numerous labs to determine if they are equipped to perform analysis on polymer samples without any success in locating one. All labs contacted to this point are environmental labs that lack the specialized equipment, such as viscometers and high pressure liquid chromatography. We are requesting that submittal of this Certificate of Analysis be delayed until prior to the first shipment, or the bid opening be delayed at least two weeks to allow for an expanded search for a properly equipped laboratory to perform relevant analysis on the polymer samples.”

Answer: Submittal of the Certificate of Analysis can be delayed until prior to the first shipment by the successful bidder.

Carol Appelt
City of Corona
Administrative Services Department
Purchasing Division
400 S. Vicentia Ave., Suite 320
Corona, CA 92882
951-279-3620